

## Certificate of Product Approval

Certificate Number: 1426g-(cl-2)

Issue: 01



### ASENWARE LTD

6 Prospect Way,  
Royal Oak Industrial Estate,  
Daventry,  
Northamptonshire,  
NN11 8PL  
United Kingdom

is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

**Control and Indicating Equipment**  
AW-FP300

(refer to Appendix for details)

#### Standards

**EN 54-2:1997 + A1:2006**

**EN 54-4:1997 + A1:2002 + A2:2006**

# ASENWARE

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

E Mattie-Suleiman  
Verifier

16 May 2018  
Date of Issue

16 May 2018  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1426g-(cl-2)

Issue: 01

### ASENWARE LTD

Certified Product	Description	LPCB Ref.No.
AW-FP300	<p>Single Loop Analogue Addressable Fire Alarm Control Panel</p> <p>Incorporating the following modules:</p> <p>SEC3002_IO IO Board</p> <p>SEC3002_B Monitoring Board (B Board)</p> <p>ZB-9100-A Main CPU Board (A Board)</p> <p>PSE10_KZ Power Supply</p> <p>SEC3002_QK Zone Indication Board</p> <p>SEC3002_KEY Key Board</p> <p>SEC3002_FL1 Loop SPU Board</p> <p>Incorporating the following optional modules:</p> <p>SEC3002_COM Communication Board</p> <p>Certified with the following options with requirements from EN54-2:</p> <p>7.8 Output to fire alarm devices</p> <p>7.10.1 Output type A</p> <p>7.11 Delays to outputs</p> <p>8.3 Fault signals from points</p> <p>9.5 Disablement of addressable point</p> <p>10 Test condition</p> <p>Notes:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13.</p> <p>2. Scope of approval does not include the operation of the network functionality.</p>	1426g/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

  
Signed for BRE Global Ltd

E Mattie-Suleiman  
Verifier

16 May 2018  
Date of Issue

16 May 2018  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



**bre**